Southern California Edison

WSD-011 – Resolution implementing the requirements of Public Utilities Code Sections 8389(d)(1), (2) and (4) related to catastrophic wildfire caused by electrical corporations subject to the Commission's regulatory authority

DATA REQUEST SET CalAdvocates-SCE-2021WMP-02

To: Cal Advocates Prepared by: Melvin Stark Job Title: Principal Manager Received Date: 1/22/2021

Response Date: 2/12/2021

Question 012:

a) How many Level 1 corrective tags were issued as a result of work verification or quality control of transmission tower detailed ground inspections in 2020?
b) How many Level 2 corrective tags were issued as a result of work verification or quality control of transmission tower detailed ground inspections in 2020?
c) Please respond to questions 12(a) through 12(b) for:
i. 2018.

ii. 2019.

Response to Question 012:

- a) SCE's T&D Quality organization performed 42 quality control (QQS) pections on transmission tower detailed ground inspections in 2019, and 67 QC inspections transmission tower detailed ground inspections in 2020. No Priority 1 or Priority 2 conditions were identified during these QC inspection 2019 or 2020. No QC inspections were performeon transmission tower detailed ground inspections in 2018.
- b) Please see the response to Question 12.a of this data request.
- c) Please see the response to Question 12.a of this data request.
 - i. N/A
 - ii. N/A