

2021 SCE Reliability Review

December 14, 2022

Livestream

Meeting Topics

- Overview of Southern California Edison (SCE)
- Reliability Definition and Measurement
- SCE's 2021 System Reliability Performance
- How to Obtain Local Reliability Reports?
- 2021 Reliability Improvements

Who We Are

- Southern California Edison (SCE) is an Edison International company
- One of the nation's largest electric utilities
- More than 130 years of history
- Headquartered in Rosemead, California
- Regulated by the California Public Utilities Commission (CPUC) and the Federal Energy Regulatory Commission (FERC)
- 50,000 square miles of SCE service area across Central, Coastal, and Southern California



How We Serve

To deliver power safely, reliably and affordably, we monitor and maintain a vast electricity system.


5M Customers and 15M Residents

445 Communities and 13 Native American Tribes

4,600 Circuits

126,000 Miles of Transmission and Distribution Lines

730,000 Transformers



Reliability Definition and Measurement

What is Reliability?

- In Simplest terms:
Having dependable electricity when you need it
- Outages:
 1. Maintenance outages (aka planned outages)
 2. Repair outages (aka unplanned outages)
 - a) Sustained Outage (>5 mins)
 - b) Momentary Outage (≤ 5 mins)
 3. Public Safety Power Shutoff (aka PSPS)



I. Major Event Day (MED): A day in which the daily system SAIDI exceeds a threshold value. For the purposes of calculating daily system SAIDI, any interruption that spans multiple calendar days is accrued to the day on which the interruption began. Statistically, days having a daily system SAIDI greater than a threshold value are days on which the energy delivery system experienced stresses beyond that normally expected (such as severe weather).

II. Public Safety Power Shutoff (PSPS): An operational protocol that SCE implements under extreme weather conditions in order to minimize the threat of wildfires and keep communities safe from potentially dangerous situations. These types of sustained outages are temporary and usually involve situations where high fire areas are experiencing adverse weather or public safety is at risk.

How Do We Measure System Reliability?

| SAIDI | SAIFI | CAIDI | MAIFI |
|-------|-------|-------|-------|
|-------|-------|-------|-------|

SAIDI = $\frac{\text{Total minutes every SCE customer was without power due to sustained outages (CMI)}}{\text{Total number of customers}}$

System Average Interruption Duration Index

“What’s the total time my power service will be unexpectedly interrupted this year?”

SAIFI = $\frac{\text{Number of sustained customer outages experienced by all SCE customers (CI)}}{\text{Total number of customers}}$

System Average Frequency Duration Index

“How many times will my power service be unexpectedly interrupted this year?”

MAIFI = $\frac{\text{Number of momentary customer outages experienced by all SCE customers (MI)}}{\text{Total number of customers}}$

Momentary Average Interruption Frequency Index

“How many times will my power service be momentarily interrupted (≤ 5 minutes) this year?”

CAIDI = $\frac{\text{System Average Interruption Duration Index (SAIDI)}}{\text{System Average Interruption Frequency Index (SAIFI)}}$

Customer Average Interruption Duration Index


“How long will it take to restore my power after an unexpected interruption?”

SCE 2021 System Reliability Performance

Energy for What's Ahead®




2012 - 2021 System Reliability History (Excluding MED¹) – Unplanned



¹Exclusions are days which utilities are allowed to remove from their metrics because the outages on those days were caused by a severe acts of nature and meet MED threshold.

2021 Outage Causes



Worst 1% of Circuits by System SAIDI

| Circuit | District | 2021 Customer Count | Substation | Circuit Miles (d) | %UG | %OH | Circuit Breaker or Auto-Recloser Operation (a) | Sys-SAIDI Rank | Sys-SAIDI (b) |
|------------------|----------|---------------------|------------------|-------------------|------|------|--|----------------|---------------|
| Mustang 12kV | 53 | 2,111 | Isabella | 51.55 | 0.04 | 0.96 | 23 | 1 | 0.584195967 |
| Tenneco 12kV* | 36 | 4,712 | Frazier Park | 124.02 | 0.21 | 0.79 | 73 | 2 | 0.57171567 |
| Pascoe 2.4kV | 53 | 409 | Greenhorn | 9.65 | 0.10 | 0.90 | 12 | 3 | 0.499969375 |
| Cuthbert 16kV* | 35 | 2,347 | Latigo | 41.84 | 0.40 | 0.60 | 42 | 4 | 0.451432658 |
| Melody 25kV | 84 | 1,947 | Hi Desert | 320.19 | - | 1.00 | 81 | 5 | 0.450066627 |
| Napoleon 12kV | 31 | 1,907 | Maraschino | 42.36 | 0.78 | 0.22 | 61 | 6 | 0.330180546 |
| Mist 16kV | 49 | 421 | Capitan | 65.69 | 0.09 | 0.91 | 40 | 7 | 0.321450218 |
| Ranger 2.4kV | 40 | 698 | Ranger P.T. | 5.19 | - | 1.00 | 15 | 8 | 0.320809853 |
| Atento 12kV* | 43 | 2,746 | Viejo | 56.78 | 0.53 | 0.47 | 44 | 9 | 0.31997025 |
| Cachuma 16kV | 49 | 2,483 | Vegas | 70.82 | 0.17 | 0.83 | 45 | 10 | 0.316458681 |
| Power 4kV | 31 | 781 | Muscoy | 11.16 | 0.03 | 0.97 | 51 | 11 | 0.315281267 |
| Eastmont 4kV* | 22 | 1,325 | Bicknell | 3.94 | 0.07 | 0.93 | 6 | 12 | 0.311647038 |
| Agate 12kV* | 43 | 4,233 | Morro | 35.48 | 0.70 | 0.30 | 39 | 13 | 0.299803232 |
| Capanero 2.4kV | 51 | 300 | Capanero P.T. | 5.31 | - | 1.00 | 6 | 14 | 0.29058599 |
| Trochu 16kV* | 32 | 2,007 | Bullis | 16.23 | 0.20 | 0.80 | 14 | 15 | 0.290247348 |
| Haskell 16kV | 27 | 1,503 | Arroyo | 26.08 | 0.45 | 0.55 | 82 | 16 | 0.285663113 |
| Abacus 12kV | 31 | 2,416 | Highland | 27.71 | 0.62 | 0.38 | 17 | 17 | 0.283265401 |
| Cabana 12kV | 30 | 2,314 | Bain | 14.52 | 0.81 | 0.19 | 17 | 18 | 0.275936149 |
| Firmona 16kV* | 44 | 1,878 | La Fresa | 7.70 | 0.16 | 0.84 | 9 | 19 | 0.266442763 |
| Thunderbolt 12kV | 36 | 1,778 | Oasis | 19.95 | 0.49 | 0.51 | 14 | 20 | 0.261041838 |
| Windjammer 16kV | 39 | 7,436 | Channel Islands | 45.26 | 0.48 | 0.52 | 22 | 21 | 0.254185161 |
| Concepcion 16kV* | 49 | 245 | Gaviota | 62.75 | 0.50 | 0.50 | 8 | 22 | 0.238098236 |
| Energy 16kV* | 35 | 1,717 | Chatsworth | 46.80 | 0.29 | 0.71 | 42 | 23 | 0.23805466 |
| Rim 12kV* | 40 | 1,886 | Burnt Mill | 29.49 | 0.22 | 0.78 | 17 | 24 | 0.237482459 |
| Courson 12kV | 36 | 2,324 | Palmdale | 21.43 | 0.85 | 0.15 | 5 | 25 | 0.237198896 |
| Landers 25kV | 84 | 1,815 | Nugget | 144.36 | 0.01 | 0.99 | 73 | 26 | 0.235553901 |
| Big Rock 16kV* | 35 | 2,993 | Chatsworth | 29.94 | 0.44 | 0.56 | 17 | 27 | 0.235498253 |
| Driskill 16kV | 49 | 4,076 | San Marcos | 68.79 | 0.41 | 0.59 | 55 | 28 | 0.233859818 |
| Roi-Tan 12kV* | 31 | 2,322 | Shandin | 28.23 | 0.31 | 0.69 | 28 | 29 | 0.233721762 |
| Canoe 12kV | 33 | 3,152 | Bolsa | 18.30 | 0.60 | 0.40 | 26 | 30 | 0.227624491 |
| Big Pines 12kV | 36 | 2,232 | Little Rock | 69.41 | 0.48 | 0.52 | 44 | 31 | 0.226117215 |
| Green Bear 2.4kV | 40 | 667 | Green Bear P.T. | 7.73 | - | 1.00 | 13 | 32 | 0.218919328 |
| Memphis 12kV | 31 | 1,456 | Tennessee | 33.27 | 0.34 | 0.66 | 43 | 33 | 0.218680086 |
| Autumn 12kV | 85 | 2,119 | Skiland | 27.14 | 0.77 | 0.23 | 21 | 34 | 0.218263219 |
| January 12kV* | 33 | 4,309 | Lafayette | 20.01 | 0.92 | 0.08 | 34 | 35 | 0.218063315 |
| Vallecito 16kV | 49 | 4,324 | Carpinteria | 55.324 | 0.47 | 0.53 | 63 | 36 | 0.21671293 |
| Milpas 16kV | 49 | 4,869 | Santa Barbara | 20.67 | 0.39 | 0.61 | 32 | 37 | 0.211738866 |
| Kay 16kV* | 22 | 2,262 | Alhambra | 15.37 | 0.31 | 0.69 | 9 | 38 | 0.201946942 |
| Exline 16kV | 22 | 4,102 | Amador | 18.23 | 0.23 | 0.77 | 28 | 39 | 0.199117449 |
| Hogan 12kV | 33 | 2,733 | Lafayette | 12.39 | 0.49 | 0.51 | 30 | 40 | 0.195785857 |
| Belpac 16kV | 35 | 3,157 | Newbury | 40.33 | 0.87 | 0.13 | 25 | 41 | 0.193430413 |
| Moritz 12kV | 40 | 1,995 | Huston | 30.32 | 0.26 | 0.74 | 43 | 42 | 0.193394162 |
| Norwood 12kV | 31 | 2,207 | Highland | 18.04 | 0.36 | 0.64 | 23 | 43 | 0.191989821 |
| Camp Nelson 4kV | 51 | 520 | Camp Nelson P.T. | 9.90 | 0.01 | 0.99 | 24 | 44 | 0.191417736 |
| Marbuck 12kV | 34 | 2,317 | Francis | 15.30 | 0.50 | 0.50 | 40 | 45 | 0.190529427 |
| Karen 12kV | 48 | 2,371 | Marion | 19.14 | 0.14 | 0.86 | 18 | 46 | 0.188654588 |

The list captures the 1% worst performing circuits (WPC) by SAIDI. It shows the total number of circuits and the associated district. Worst performing circuits are calculated based on a historical three-year weighted average and excludes MEDs

Worst 1% of Circuits by System SAIFI

| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------------------|----------|---------------------|-----------------|-------------------|------|------|--|----------------|---------------|
| Circuit | District | 2021 Customer Count | Substation | Circuit Miles (d) | %UG | %OH | Circuit Breaker or Auto-Recloser Operation (a) | Sys-SAIFI Rank | Sys-SAIFI (b) |
| Tenneco 12kV* | 36 | 4,712 | Frazier Park | 124.02 | 0.21 | 0.79 | 73 | 1 | 0.00374 |
| Corsica 16kV* | 39 | 6,523 | Gonzales | 47.21 | 0.62 | 0.38 | 26 | 2 | 0.00329 |
| Windjammer 16kV* | 39 | 7,436 | Channel Islands | 45.26 | 0.48 | 0.52 | 22 | 3 | 0.00306 |
| January 12kV* | 33 | 4,309 | Lafayette | 20.01 | 0.92 | 0.08 | 34 | 4 | 0.00286 |
| Blimp 16kV | 32 | 3,674 | Nola | 30.50 | 0.23 | 0.77 | 28 | 5 | 0.00283 |
| Margaret 16kV | 44 | 5,224 | Felton | 16.71 | 0.27 | 0.73 | 18 | 6 | 0.00227 |
| Salmon 16kV* | 44 | 3,971 | El Nido | 18.46 | 0.42 | 0.58 | 21 | 7 | 0.00227 |
| Spinnaker 16kV* | 39 | 5,080 | Channel Islands | 34.19 | 0.29 | 0.71 | 23 | 8 | 0.00219 |
| Roi-Tan 12kV* | 31 | 2,322 | Shandin | 28.23 | 0.31 | 0.69 | 28 | 9 | 0.00219 |
| Driskill 16kV | 49 | 4,076 | San Marcos | 68.79 | 0.41 | 0.59 | 55 | 10 | 0.00209 |
| Milpas 16kV | 49 | 4,869 | Santa Barbara | 20.67 | 0.39 | 0.61 | 32 | 11 | 0.00208 |
| Marbuck 12kV | 34 | 2,317 | Francis | 15.30 | 0.50 | 0.50 | 40 | 12 | 0.00207 |
| Kuehner 16kV* | 35 | 3,070 | Santa Susana | 23.98 | 0.77 | 0.23 | 18 | 13 | 0.00207 |
| Ricardo 16kV* | 39 | 2,982 | San Miguel | 23.21 | 0.39 | 0.61 | 44 | 14 | 0.00206 |
| Napoleon 12kV | 31 | 1,907 | Maraschino | 42.36 | 0.78 | 0.22 | 61 | 15 | 0.00205 |
| Gringo 16kV | 39 | 4,736 | San Miguel | 28.68 | 0.90 | 0.10 | 31 | 16 | 0.00203 |
| Agate 12kV | 43 | 4,233 | Morro | 35.48 | 0.70 | 0.30 | 39 | 17 | 0.00202 |
| Tri City 16kV* | 22 | 3,153 | Alhambra | 17.01 | 0.26 | 0.74 | 19 | 18 | 0.00200 |
| Exline 16kV | 22 | 4,102 | Amador | 18.23 | 0.23 | 0.77 | 28 | 19 | 0.00198 |
| Vallecito 16kV | 49 | 4,324 | Carpinteria | 55.51 | 0.47 | 0.53 | 63 | 20 | 0.00196 |
| Fantail 16kV* | 42 | 5,839 | Tahiti | 12.90 | 0.87 | 0.13 | 9 | 21 | 0.00195 |
| Haskell 16kV | 27 | 1,503 | Arroyo | 26.08 | 0.45 | 0.55 | 82 | 22 | 0.00195 |
| Ambrus 16kV | 27 | 2,335 | Bradbury | 19.46 | 0.67 | 0.33 | 23 | 23 | 0.00193 |
| Hooligan 16kV | 35 | 3,164 | Newbury | 48.48 | 0.85 | 0.15 | 26 | 24 | 0.00192 |
| Sweetwater 12kV | 31 | 3,361 | Shandin | 33.32 | 0.92 | 0.08 | 24 | 25 | 0.00191 |
| Campanula 25kV* | 84 | 1,979 | Nugget | 135.78 | 0.07 | 0.93 | 89 | 26 | 0.00187 |
| Kalmia 16kV | 32 | 2,850 | Calden | 15.36 | 0.05 | 0.95 | 23 | 27 | 0.00186 |
| Ryan 16kV | 44 | 7,018 | Lennox | 27.13 | 0.20 | 0.80 | 10 | 28 | 0.00185 |
| Sundown 12kV* | 73 | 2,578 | Helendale | 46.98 | 0.85 | 0.15 | 26 | 29 | 0.00184 |
| Diablo 16kV | 39 | 4,284 | San Miguel | 36.71 | 0.60 | 0.40 | 29 | 30 | 0.00177 |
| Queensland 12kV | 36 | 2,437 | Lancaster | 26.74 | 0.71 | 0.29 | 20 | 31 | 0.00176 |
| Surfside 16kV | 39 | 5,623 | Channel Islands | 31.50 | 0.62 | 0.38 | 28 | 32 | 0.00171 |
| Wintersburg 12kV | 33 | 3,651 | Oceanview | 17.23 | 0.56 | 0.44 | 5 | 33 | 0.00168 |
| Trochu 16kV* | 32 | 2,007 | Bullis | 16.23 | 0.20 | 0.80 | 14 | 34 | 0.00168 |
| Asteroid 16kV* | 22 | 4,430 | Alhambra | 20.74 | 0.36 | 0.64 | 15 | 35 | 0.00165 |
| Big Rock 16kV* | 35 | 2,993 | Chatsworth | 29.94 | 0.44 | 0.56 | 17 | 36 | 0.00164 |
| Kwis 12kV* | 26 | 2,101 | Walnut | 26.64 | 0.54 | 0.46 | 27 | 37 | 0.00162 |
| Mallet 12kV | 26 | 2,723 | Railroad | 29.35 | 0.69 | 0.31 | 35 | 38 | 0.00162 |
| Power 4kV | 31 | 781 | Muscoy | 11.16 | 0.03 | 0.97 | 51 | 39 | 0.00160 |
| Belpac 16kV | 35 | 3,157 | Newbury | 40.33 | 0.87 | 0.13 | 25 | 40 | 0.00157 |
| Tandem 16kV | 44 | 1,975 | Walteria | 18.92 | 0.41 | 0.59 | 20 | 41 | 0.00156 |
| Seminary 16kV | 39 | 2,086 | Somis | 22.01 | 0.46 | 0.54 | 17 | 42 | 0.00153 |
| Campbell 12kV* | 51 | 2,622 | Porterville | 114.73 | 0.24 | 0.76 | 26 | 43 | 0.00152 |
| Speaker 12kV | 33 | 4,809 | Hamilton | 31.76 | 0.61 | 0.39 | 12 | 44 | 0.00151 |
| Rhumba 16kV | 44 | 4,121 | Brighton | 16.76 | 0.34 | 0.66 | 10 | 45 | 0.00150 |
| McDonnell 16kV | 44 | 2,017 | Lennox | 12.78 | 0.31 | 0.69 | 19 | 46 | 0.00150 |

The list captures the 1% worst performing circuits (WPC) by SAIFI. It shows the total number of circuits and the associated district. Worst performing circuits are calculated based on a historical three-year weighted average and excludes MEDs

How to Obtain Local Reliability Reports

How can I get Reliability Information?


- City Reliability Reports can be found **at SCE > Outage Center > Reliability Reports**
- There are over 240 City Reliability Presentations available, including unincorporated cities
- These reports are updated annually
- City Reliability Reports include the following information:
 - Listing of circuits serving that city
 - Circuit reliability performance
 - Causes of repair outages on those circuits
 - Capital Improvement Plans on those circuits
 - Historical SAIDI/SAIDI for circuits

City Overview and Reliability Reports

- Each city report will list all circuits that serve that city as well as the number of customers on each of those circuits
- Provides reliability history for the current year and the prior 3 years
 - SAIDI
 - SAIFI
 - MAIFI

Overview of Anytown
There are 20 circuits that serve Anytown


| Circuit Type | Sum of Customers | Circuit Type | Sum of Customers | Circuit Type | Sum of Customers |
|--------------------|------------------|--------------|------------------|--------------|------------------|
| BECH(20KV) | 2 | | | | |
| ELMHTO(4.20KV) | 1,486 | | | | |
| ELMHTO(4.20KV) | 330 | | | | |
| CELEBRE(20KV) | 376 | | | | |
| EXPRES(12KV) | 1 | | | | |
| FRTO(12KV) | 1 | | | | |
| FRHTN(20KV) | 414 | | | | |
| HUBVOT(12KV) | 2,437 | | | | |
| JUDY(12KV) | 325 | | | | |
| LAUTERBACH(4.20KV) | 237 | | | | |
| MHJ(12KV) | 1,389 | | | | |
| MIDWAY(20KV) | 1 | | | | |
| RATON(12KV) | 545 | | | | |
| RESID(20KV) | 1,803 | | | | |
| ROCCO(12KV) | 18 | | | | |
| ROUCE(12KV) | 800 | | | | |
| ROULN(20KV) | 881 | | | | |
| ROVOT(12KV) | 34 | | | | |
| THOMAS(20KV) | 872 | | | | |
| TURKEY(12KV) | 390 | | | | |
| Grand Total | 32,627 | | | | |



Outage Causes


Each report will provide the % contribution by SAIDI and SAIFI based on the outage cause categories

- 3rd Party
- Equipment Failure
- Operation
- Other
- Vegetation/Animal
- Weather/Fire/Earthquake
- PSPS




Circuit Maps

- The report provides a map of all the circuits that serve the jurisdiction, including PSPS circuits



Capital Improvement Map

- The capital improvement map has transitioned to a virtual format via SCE's capital improvements and can be accessed using the link www.sce.com/CapitalImprovements.



2021 Reliability Improvements

Energy for What's Ahead®



2021 Infrastructure Improvements

SCE plans to spend more than \$5B each year to maintain, improve, and harden its infrastructure by focusing on the following areas:

- **Infrastructure reliability** – updating underground cables, poles, switches, and transformers
- **Wildfire mitigation** – hardening infrastructure, bolstering situational awareness capabilities, and enhancing operational practices
- **Transmission** – connecting renewables, installing new substations, and updating lines
- **Grid readiness** – updating the grid for impacts from new technologies
- **Long-term energy policy** – supporting energy storage, electric vehicles, and renewables

2021 Capital Investment

- 235 miles of underground cable replaced
- 97 miles of overhead conductor replaced for public safety
- 11.1k distribution poles replaced
- 3.6k transmission poles replaced
- 79 underground structure replacements



Addressing Wildfire Risk

SCE will continue to further strengthen the system and provide customer assistance and resources to make communities safer, more resilient, and minimize the impact of PSPS events

Measures to reduce wildfire risks include:

- Inspecting and investing in electric equipment and infrastructure
- Improving situational awareness capabilities
- Managing vegetation around electric infrastructure
- Implementing Public Safety Power Shutoffs (PSPS) during potentially dangerous weather conditions






Wildfire Mitigation Activities SCE SERVICE AREA

2021 Year-End Progress Report

Data as of 12/31/21



**Distribution
Equipment
Inspections**

2021
Completed/Target
179,600/163,000
inspections

✓ **110%**
completed

Completed
Since 2018
764,000+
inspections




**Transmission
Equipment
Inspections**

2021
Completed/Target
20,800/16,800
inspections

✓ **124%**
completed

Completed
Since 2018
106,900+
inspections



**Insulated Wire
(Covered Conductor)**

2021
Completed/Target
1,500/1,000
circuit miles installed

✓ **150%**
completed

Completed
Since 2018
2,900+
circuit miles installed



Fast-Acting Fuses

2021
Completed/Target
350/330
fuses installed or
replaced

✓ **106%**
completed

Completed
Since 2018
13,300+
fuses installed or
replaced



**Hazard Tree
Management**

2021
Completed/Target
131,400/120,000
trees assessed

✓ **110%**
completed

Completed
Since 2018
359,900+
trees assessed



**Weather
Stations**

2021
Completed/Target
400/375
weather stations
installed

➔ **107%**
completed

Completed
Since 2018
1,460+
weather stations
installed



**High-Definition
Wildfire Cameras**


Cameras currently provide
visibility to about 90% of our
high fire risk areas (HFRA)
and the planned additional
cameras in 2022 and beyond
will increase coverage to
nearly all of HFRA

Completed
Since 2018
166
cameras installed



**Aerial Fire
Suppression
Resources**

SCE contributed \$18 million to support the creation of
a quick reaction force of aerial firefighting assets
across counties in SCE's service area to coordinate
and reach wildfires in their early stages. These unique
water and fire retardant dropping helitankers have
the capability to operate day and night.



**Critical Care
Backup Battery**

2021
Completed
6,000/3,600
batteries provided
to eligible customers

✓ **167%**
completed

Completed Since
July 2020
6,740+
batteries provided
to eligible customers



**Community
Resource Centers**

64
sites
available



**Community Crew
Vehicles**

8
vehicles
available

Questions?

Contact
CircuitReliability@sce.com