

Southern California Edison

WSD-011 – Resolution implementing the requirements of Public Utilities Code Sections 8389(d)(1), (2) and (4) related to catastrophic wildfire caused by electrical corporations subject to the Commission’s regulatory authority

DATA REQUEST SET CalAdvocates - SCE - 2021 WMP - 02

To: Cal Advocates
Prepared by: Raymond Fugere
Job Title: Principal Manager
Received Date: 1/22/2021

Response Date: 2/12/2021

Question 008:

- a) How many Level 1 corrective tags were issued as a result of transmission tower drone inspections in 2020?
- b) How many Level 2 corrective tags were issued as a result of transmission tower drone inspections in 2020?
- c) Please respond to questions 8(a) through 8(b) for:
 - i. 2018.
 - ii. 2019.

Response to Question 008:

SCE’s aerial program was launched in 2019 and does not differentiate if a repair notification was captured from a helicopter or a drone. The table, below, contains pending and completed repair notifications identified in SCE’s system of record on a tower as the result of an aerial inspection.

Year	Priority 1	Priority 2
2019	6	1,027
2020	41	412