

Southern California Edison

WSD-011 – Resolution implementing the requirements of Public Utilities Code Sections 8389(d)(1), (2) and (4) related to catastrophic wildfire caused by electrical corporations subject to the Commission’s regulatory authority

DATA REQUEST SET CalAdvocates - SCE - 2021 WMP - 13

To: Cal Advocates
Prepared by: Raymond Fugere
Job Title: Principal Manger
Received Date: 3/15/2021

Response Date: 3/17/2021

Question 002:

Using the table below, disaggregate the number of Level 2 findings in HFTD for detailed distribution inspections that were reported by SCE in Line 1.h of Table 1 of SCE’s non-spatial WMP data tables into each type of inspection that is included in line 1.h.

	Mitigation Activity	2015	2016	2017	2018	2019	2020
1.h.	Total Level 2 findings in HFTD for detailed inspections - Distribution lines	7,297	7,751	5,841	4,813	7,283	23,964
	Ex: Ground Inspections						
	Ex: Aerial Inspections						

Response to Question 002:

As noted in SCE’s response to CalAdvocates-SCE-2021WMP-09-008, the numbers in Table 1 contained errors. The below table contains the corrected numbers and the requested breakdown, based upon the data contained in SCE’s system of record.

Mitigation Activity	2015	2016	2017	2018	2019	2020
Total Level 2 findings in HFTD for detailed inspections - Distribution Lines	7,297	7,751	5,841	16,646	71,791	28,454
Ground Inspections	7,297	7,750	5,841	16,645	64,287	23,934
Aerial Inspections	0	1	0	1	7,504	4,520