

Southern California Edison

WSD-011 – Resolution implementing the requirements of Public Utilities Code Sections 8389(d)(1), (2) and (4) related to catastrophic wildfire caused by electrical corporations subject to the Commission’s regulatory authority

DATA REQUEST SET T U R N - S C E - 0 0 3

To: TURN

Prepared by: Raymond Fugere

Job Title: Principal Manager

Received Date: 2/24/2021

Response Date: 3/2/2021

Question 003:

Please provide the number of overhead distribution circuit miles located in Tiers 1, 2 and 3 and non-HFTD areas, at the end of each year 2018, 2019 and 2020.

Response to Question 003:

The below table contains the overhead distribution circuit miles by year and fire designation.

OH Distribution Circuit Miles	Non-HFTD	HFTD Zone 1	HFTD Tier 2	HFTD Tier 3
2018	29,222	2	3,877	5,774
2019	29,406	2	4,054	5,774
2020	29,187	2	3,997	5,716