

Southern California Edison
2022-WMPs – 2022 Wildfire Mitigation Plan Updates

DATA REQUEST SET Cal Advocates - SCE - 2022 WMP - 16 A

To: Cal Advocates
Prepared by: Jonathan Brownstein
Job Title: Engineering Manager
Received Date: 8/17/2022

Response Date: 8/30/2022

Question 01:

- a) How many total ignitions has SCE experienced related to overhead covered conductor distribution lines from January 1, 2015 through July 31, 2022?
- b) How many total ignitions has SCE experienced related to overhead bare conductor distribution lines from January 1, 2015 through July 31, 2022?
- c) How many total ignitions has SCE experienced related to underground distribution lines from January 1, 2015 through July 31, 2022?

Response to Question 01:

- a) SCE has experienced four (4) CPUC reportable ignitions related to overhead covered conductor primary distribution lines from January 1, 2015 through July 31, 2022. Please note that SCE began installing covered conductor to mitigate wildfire risk in 2018.
- b) SCE has experienced 663 CPUC reportable ignitions related to overhead bare conductor primary distribution lines from January 1, 2015 through July 31, 2022.
- c) SCE has experienced 23 CPUC reportable ignitions related to underground distribution primary lines from January 1, 2015 through July 31, 2022.