

*Southern California Edison*  
*2025-WMPs – 2025-WMPs*

**DATA REQUEST SET Cal Advocates - SCE - 2025 WMP - 06**

**To: Cal Advocates**  
**Prepared by: Cindy Jacobs**  
**Job Title: Senior Manager**  
**Received Date: 4/15/2024**

**Response Date: 4/18/2024**

---

**Question 13:**

- a) How many overdue P3 notification tags are there today in SCE's system?  
b) Please break down the overdue P3 notification tags by the reason for lateness and by age.

**Response to Question 13:**

*a) How many overdue P3 notification tags are there today in SCE's system?*

The CPUC revised GO 95 and instituted 5-year due dates for level 3 infractions beginning mid-year 2019. Accordingly, the first notifications to have a due date under applicable CPUC rules will not be due until mid-year 2024. Prior to mid-year 2019, Level 3 (equivalent to SCE's P3) did not have due dates and were considered opportunity maintenance. With those clarifications, there are 505 P3 notifications in the system that have a due date prior to the Commission mandated implementation. There are several ways this could happen. For example, a notification could have originally been created as a P2 and then subsequently changed to a P3. If the due date was not also changed, the result would be a P3 with a due date earlier than mid-year 2024.

*b) Please break down the overdue P3 notification tags by the reason for lateness and by age.*

Table One – Breakdown by Age

Row Labels	Count of Notification
0-30 days	43
31-60 days	7
61-90 days	7
> 90 days	448
<b>Grand Total</b>	<b>505</b>

Table Two – Breakdown by Reason

Row Labels	Count of Notification
Inactive Equipment	322
Further Analysis Required	142
GO95 Exceptions	34
Work complete pending notification closure	7
<b>Grand Total</b>	<b>505</b>