

*Southern California Edison*  
*R.18-10-007 – SB 901*

**DATA REQUEST SET C E J A - S C E - 0 0 1**

**To: CEJA**  
**Prepared by: Breanna Medina**  
**Job Title: Advisor**  
**Received Date: 2/15/2019**

**Response Date: 2/22/2019**

---

**Question 5:** 5. San Diego Gas & Electric Company's plan has a warning system that allows for advanced preparation in the event of potential wildfire and/or deenergization conditions. Do you plan to have a similar warning system? If so, please describe your planned system. If not, please describe why not?

**Response to Question 5:**

SCE has an established response plan for wildfire operations that includes using situational awareness tools to regularly monitor predicted weather in the service territory, inform the need for necessary response operations and conduct on-going communications for early warning of possible impacts to its ability to safely provide power. Within 48 hours of a potential event forecasted in the service territory, SCE makes every attempt to establish and maintain on-going communications with stakeholders; including public safety agencies, local government officials and customers that may potentially be impacted by the need for pro-active de-energization. This advance warning allows time for collaboration on the impacts that potential de-energization may have on both local communities and individuals. Additional ongoing communications on the status of any actual pro-active de-energizations is continuously shared with stakeholders through the duration of the incident until power is restored and response operations are no longer necessary.