

Southern California Edison

R.18-10-007 – Order Instituting Rulemaking to Implement Electric Utility Wildfire Mitigation Plans Pursuant to Senate Bill 901 (2018).

DATA REQUEST SET M G R A - S C E - 0 0 3

To: MGRA

Prepared by: Raymond Fugere

Job Title: Senior Manager

Received Date: 9/27/2019

Response Date: 10/10/2019

Question 44:

What “cause” classifications does SCE currently use for classifying wire-down event data?

Response to Question 44:

SCE uses the term “Triggering Events” to refer to the identified cause of a wire down event. Below is a list of triggering events for wire-down events:

Triggering Event
Vegetation
Unknown
Other Environmental Factor
Connector/Splice Failure
Other Equipment Failure
Other Public Action
Car Hit
Animal
Crossarm Failure
Weather
Mylar Balloon
SCE Work/Operation
Pole Damaged
Non-Compliance
Tree Trimmer
Other
Damaged Wire
Corrosion/Deterioration
Damaged Tap
Lightning Arrester