

Southern California Edison

WSD-011 – Resolution implementing the requirements of Public Utilities Code Sections 8389(d)(1), (2) and (4) related to catastrophic wildfire caused by electrical corporations subject to the Commission’s regulatory authority

DATA REQUEST SET W S D - S C E - 0 0 2

To: WSD

Prepared by: Cameron McPherson

Job Title: Advisor, Business Operations Analysis

Received Date: 3/1/2021

Response Date: 3/3/2021

Question 003:

Enter the total circuit miles for each category in the following table. HFTD = High Fire Threat District, Tx = Transmission Lines, Dx = Distribution Lines, OH = Overhead, UG = Underground

Location	Tx-OH	Tx-UG	Dx-OH	Dx-UG	TOTAL
<i>Non-HFTD</i>					
<i>HFTD-Zone 1</i>					
<i>HFTD-Tier 2</i>					
<i>HFTD-Tier 3</i>					
TOTAL					

Response to Question 003:

Please find the requested data in the table below.

Location	Tx-OH	Tx-UG	Dx-OH	Dx-UG	TOTAL
<i>Non-HFTD</i>	8,421	284	29,187	23,569	61,461
<i>HFTD-Zone 1</i>	-	-	2	7	9
<i>HFTD-Tier 2</i>	1,960	21	3,997	2,826	8,804
<i>HFTD-Tier 3</i>	2,325	41	5,716	4,162	12,244
TOTAL	12,706	346	38,902	30,564	82,518