

Southern California Edison
2023-WMPs – 2023-WMPs

DATA REQUEST SET T U R N - S C E - 0 0 2

To: TURN
Prepared by: Hunly Chy
Job Title: Senior Manager
Received Date: 4/26/2023

Response Date: 5/1/2023

Question 04:

For the undergrounding work described in SCE's 2023-2025 WMP, please describe SCE's policy concerning undergrounding of secondary distribution lines (as opposed to primary lines) and the removal of poles on which secondary lines are attached. To the extent that this determination varies by project, please describe the criteria that SCE uses to decide whether SCE undergrounds secondary lines in a given location.

Response to Question 04:

All secondary lines that run along the same path or attached to the targeted undergrounding scope are designed to be placed underground, where feasible.

If the secondary lines are undergrounded, and there is no other 3rd party attachment (i.e., telecommunication lines or equipment) to the pole, the pole would be scoped for removal.