

Southern California Edison
2025-WMPs – 2025-WMPs

DATA REQUEST SET CalAdvocates - SCE - 2025 WMP - 03

To: Cal Advocates
Prepared by: Amber Beaulieu
Job Title: Advisor
Received Date: 3/22/2024

Response Date: 4/12/2024

Question 17:

On page 332 of your 2023 – 2025 WMP, SCE provided a table (Table 8.8c) showing the total number of “ignition risk” past due asset work orders by age and HFTD tier, excluding GO 95 exceptions. Please provide an updated version of Table 8.8c, as of March 1, 2024. A blank table is provided below for your reference.

Response to Question 17:

Question 17 Table					
Tier	0 – 30 Days	31 – 90 Days	90 – 180 Days	181+	Total
HFTD 2	3	68	23	913	1,007
HFTD 3	142	251	270	1,746	2,409
Total	345	319	293	2,659	3,416

As stated in SCE’s 2025 WMP Update, ACI-23-13, in addition to its typical management of GO 95 notifications, SCE is also taking a risk-based approach in re-validating that the top 50% of notifications remain constrained by external factors. The goal is that the additional scrutiny will help determine whether some constraints that are being held by government agencies, local public authorities, etc., can be more rapidly resolved.