

Application No.: 18-09-002  
Exhibit No.: SCE-01A-Amended  
Witnesses: B. Chiu  
D. Daigler  
P. Herrington  
M. Jocelyn  
L. Letizia  
D. Tessler  
T. Tran



(U 338-E)

***Amended Prepared Testimony in Support of Southern  
California Edison Company's Application for Approval of Its  
Grid Safety and Resiliency Program - Annotated***

Before the

**Public Utilities Commission of the State of California**

Rosemead, California  
November 2, 2018

**Table IV-8**  
**Breakdown of Contact from Object and Equipment/Facility Failure Related**  
**Faults (Distribution Voltage Infrastructure in HFRA from 2015-2017)<sup>85</sup>**

Suspected Initiating Event	Previous		Current	
	Count	Percentage	Count	Percentage
Contact From Object	895	31.75%	973	31.84%
Equipment/Facility Failure	1,354	48.03%	1,459	47.74%
Other	571	20.26%	624	20.42%
<b>Total</b>	<b>2,819</b>	<b>100.00%</b>	<b>3,056</b>	<b>100.00%</b>
Contact From Object	Count	Percentage	Count	Percentage
Animal	250	8.87%	272	8.90%
Balloons	152	5.39%	167	5.46%
Other	48	1.70%	51	1.67%
Vegetation	238	8.44%	256	8.38%
Vehicle	207	7.34%	227	7.43%
<b>Total</b>	<b>895</b>	<b>31.75%</b>	<b>973</b>	<b>31.84%</b>
Equipment/Facility Failure	Count	Percentage	Count	Percentage
Capacitor Bank	8	0.28%	9	0.29%
Conductor	145	5.14%	163	5.33%
Crossarm	39	1.38%	43	1.41%
Fuse	98	3.48%	104	3.40%
Insulator	24	0.85%	26	0.85%
Other	111	3.94%	117	3.83%
Splice/Clamp/Connector	138	4.90%	154	5.04%
Transformer	791	28.06%	843	27.59%
<b>Total</b>	<b>1,354</b>	<b>48.03%</b>	<b>1,459</b>	<b>47.74%</b>

SCE then mapped the fire ignition data, including information regarding the cause of each fire (where known), to the cause codes in ODRM. This process allowed SCE to connect data regarding the frequency of faults of different types to data regarding the frequency of fires associated with those fault types. From this analysis, SCE extrapolated the likelihood that a given type of fault could be associated with a fire ignition event.

<sup>85</sup> Note, this table presents data related to faults. See Table III-5 for data associated with fires. SCE-01A (A. 18-09-002) was based on incomplete ODRM source data. It did not include the last 2½ months of 2017 (10-13-2017 through 12-31-2017). This table now reflects the additional data. As shown, the percentages do change when not rounded, but when rounded and shown as an integer then no change would be visible to the percentages. The impact is minimal for two reasons, (1) the additional 2 ½ months of fault data added were not significant in quantity and (2) the additional 2 ½ months of fault data added has a similar distribution to the initial data.

1 The results showed that contact from object faults have a higher  
2 probability of being associated with a fire event: this broad category accounted for less than one-  
3 third of total faults in SCE's system (32 percent) but was associated with more than one-half (53  
4 percent) of the suspected wildfire initiating event types. This pointed to a potential opportunity  
5 for significantly reducing wildfire risk by focusing on measures that prevent contact-related  
6 faults. Vegetation-related CFO faults provides a specific example. In the 2015-2017 period, the  
7 ODRM fault analysis shows that there were ~~2,819~~ 3,056 faults per year on the distribution  
8 system in HFRA; ~~238~~ 256 of these, or eight percent, were identified as vegetation-related CFO  
9 faults. In that same period, fire data analysis shows that there were approximately 132 fires  
10 associated with the distribution system in HFRA;<sup>86</sup> for 22 of these, or 16.7 percent, vegetation  
11 contact was identified as the suspected initiating event. Note that these numbers do not include  
12 fires that are still being investigated and for which the suspected origin and cause are still  
13 undetermined. Thus, all else equal, there was a relatively greater likelihood that a vegetation-  
14 related fault was ultimately associated with a fire event.

15 (2) Risk Analysis: Mitigation-to-Fault Mapping

16 The next step in the risk analysis performed by SCE was a  
17 mapping of specific mitigation alternatives to the types of faults that can be avoided upon  
18 deployment. This analysis relied on engineering subject matter expertise to identify how much  
19 of each general fault type—contact from object, equipment/facility failure, and other—would be  
20 mitigated by a specific mitigation measure. It focused on three key mitigation measures: (1) re-  
21 conductor with bare conductor sized to meet current design standards; (2) re-conductoring  
22 with covered conductor sized to meet current design standards; and (3) relocating distribution  
23 lines underground. For example, all three of these mitigation measures were identified as  
24 effective at mitigating the splice/connector/tap subtype of equipment failure faults. Two of these  
25 three mitigation measures (covered conductor and underground conversion) were identified as

---

<sup>86</sup> This figure is approximate since some fires during this period are still under investigation.