Southern California Edison

WSD-011 – Resolution implementing the requirements of Public Utilities Code Sections 8389(d)(1), (2) and (4) related to catastrophic wildfire caused by electrical corporations subject to the Commission's regulatory authority

DATA REQUEST SET CalAdvocates-SCE-2021WMP-10

To: Cal Advocates Prepared by: Kyle Ferree Job Title: Senior Advisor Received Date: 3/8/2021

Response Date: 3/11/2021

Question 001.a-d and g-h:

Regarding SCE's program of personnel monitoring areas of electric lines and equipment in elevated fire risk conditions (WMP Section 7.3.2.5):

- A) Of the 1,904 patrols performed under that heading, what number were pre-event patrols?
- B) Of the 1,904 patrols performed under that heading, what number were restoration patrols?
- C) Does the program include any patrols other than pre-event patrols and restoration patrols?
- D) If the answer to (C) is yes, please describe those patrols.
- G) Please provide an estimate of the average duration (in hours and minutes) of a pre-event patrol described under Section 7.3.2.5.
- H) Please provide an estimate of the average duration (in hours and minutes) of a restoration patrol described under Section 7.3.2.5.

Response to Question 001.a-d and g-h:

- A) 1,461 of the patrols performed were pre-patrols.
- B) 443 of the patrols performed were post-patrols.
- C) SCE's live field observations (LFOs) are also included in the program work under "personnel monitoring areas of electric lines and equipment in elevated fire risk conditions" but are not captured in the count of 1,904 patrols.
- D) Please see Section 7.3.2.5 of SCE's 2021 WMP Update for a description of SCE's live field observations.
- G) Pre-patrol average duration in 2020 was 3 hours and 37 minutes.
- H) Post-patrol average duration in 2020 was 6 hours and 31 minutes.