

Southern California Edison
2023-WMPs – 2023-WMPs

DATA REQUEST SET CalAdvocates - SCE - 2023 WMP - 05

To: Cal Advocates
Prepared by: Bryan Landry
Job Title: Senior Advisor – Strategic Planning
Received Date: 2/10/2023

Response Date: 2/27/2023

Question 01:

Risk Modeling:

- a) Have you identified transportation corridors within your service territory where falling or failing lines or poles could currently limit egress and/or ingress during an emergency?
- b) If the answer to part (a) is yes, please describe how you identify such transportation corridors.
- c) If available, please provide a geospatial data file that contains all current identified transportation corridors with ingress and egress hazards.

Response to Question 01:

- a.) No. SCE's egress model does not rely on the identification of locations where falling or failing lines of poles could limit egress or egress during an emergency. SCE's egress model, instead, relies on the relative ranking of population density in relation to road availability. See Section 6 of SCE's 2023-2025 pre-submission WMP for additional information.
- b.) Not applicable
- c.) Not applicable