

Southern California Edison
2025-WMPs – 2025-WMPs

DATA REQUEST SET M G R A - S C E - W M P 2 3 _ D a t a R e q u e s t 2

To: MGRA
Prepared by: Trang L Woo
Job Title: Engineer 3
Received Date: 4/8/2024

Response Date: 4/10/2024

Question 04:

Please provide a list of outages for the last two years including the following additional attributes:

- a. whether circuit was implemented with active Fast Curve Settings
- b. whether circuit was implemented with active REFCL
- c. whether circuit was implemented with active EFD

Response to Question 04:

Please see the attached Excel spreadsheet and note the following:

a "Y" response means that in at least one portion of the circuit, the technology (i.e. Fast Curve, REFCL, or EFD) was installed and enabled. Because REFCL, Fast Curve, and EFD do not necessarily cover or protect an entire circuit, a "Y" response in a column should not be interpreted to mean that the device or protection strategy was active at the specific location of the outage.