

*Southern California Edison*  
*2022-WMPs – 2022 Wildfire Mitigation Plan Updates*

**DATA REQUEST SET Cal Advocates - SCE - 2022 WMP - 16 A**

**To: Cal Advocates**  
**Prepared by: Jonathan Brownstein**  
**Job Title: Engineering Manager**  
**Received Date: 8/17/2022**

**Response Date: 8/30/2022**

---

**Question 02:**

Please complete Table 2a below, including only ignitions related to overhead covered conductor distribution lines on your system.

Table 2a Ignitions Related to Overhead Covered Conductor Distribution Lines								
	2015	2016	2017	2018	2019	2020	2021	2022 (January – July)
HFTD Tier 3								
HFTD Tier 2								
Other HFTD								
Non-HFTD								

- b) Please complete Table 2b below, including only ignitions related to overhead bare conductor distribution lines on your system.

Table 2b Ignitions Related to Overhead Bare Distribution Lines								
	2015	2016	2017	2018	2019	2020	2021	2022 (January – July)
HFTD Tier 3								
HFTD Tier 2								
Other HFTD								
Non-HFTD								

c) Please complete Table 2c below, including only ignitions related to underground distribution lines on your system.

Table 2c Ignitions Related to Underground Distribution Lines								
	2015	2016	2017	2018	2019	2020	2021	2022 (January - July)
HFTD Tier 3								
HFTD Tier 2								
Other HFTD								
Non-HFTD								

### Response to Question 02:

a)

Table 2a CPUC Reportable Ignitions Related to Overhead Covered Conductor Distribution Lines								
	2015	2016	2017	2018	2019	2020	2021	2022 (January - July)
HFTD Tier 3	0	0	0	0	0	0	0	1
HFTD Tier 2	0	0	0	0	0	0	2	1
Other HFTD	0	0	0	0	0	0	0	0
Non-HFTD	0	0	0	0	0	0	0	0

Table 2a data is based on CPUC Reportable ignitions on the primary distribution system related to covered conductor on the system. Please note that in 2019 SCE improved its data collection capabilities concerning ignitions and in part captured additional features, whereas years prior relied upon various systems of record to differentiate primary covered conductor distribution ignitions.

b)

Table 2b CPUC Reportable Ignitions Related to Overhead Bare Distribution Lines								
	2015	2016	2017	2018	2019	2020	2021	2022 (January - July)
HFTD Tier 3	24	23	18	18	17	20	14	7
HFTD Tier 2	7	9	8	12	12	7	10	7
Other HFTD	5	4	10	8	1	0	0	0
Non-HFTD	49	38	42	55	62	66	79	31

Table 2b data is based on CPUC Reportable ignitions on the primary distribution system related to bare conductor on the system. Please note that in 2019 SCE improved its data collection capabilities concerning ignitions and in part captured additional features, whereas years prior relied upon various systems of record to differentiate primary bare distribution ignitions.

c)

Table 2c CPUC Reportable Ignitions Related to Underground Distribution Lines								
	2015	2016	2017	2018	2019	2020	2021	2022 (January - July)
HFTD Tier 3	1	1	0	3	0	0	1	0
HFTD Tier 2	0	0	0	0	0	0	0	0
Other HFTD	0	1	0	0	0	0	0	0
Non-HFTD	1	2	0	0	2	2	6	3

Table 2c data is based on CPUC Reportable ignitions on the primary distribution system related to underground on the system. Please note that in 2019 SCE improved its data collection capabilities concerning ignitions and in part captured additional features, whereas years prior relied upon various systems of record to differentiate primary underground distribution ignitions.