

Southern California Edison
2025-WMPs – 2025-WMPs

DATA REQUEST SET CalAdvocates-SCE-2025WMP-09


To: Cal Advocates
Prepared by: Mike Freeman
Job Title: Sr. Advisor
Received Date: 4/23/2024

Response Date: 4/26/2024

Question 02:

Questions 2 - 4 pertain to SCE's response to data request CalAdvocates-SCE-2025WMP-03, question 1. SCE provides the following screenshot of an asset inspection quality control (QC) dashboard:

Overhead Detailed Inspection – 2023 Results



The screenshot contains a graphic that uses the term “high and moderate non-conformant structures.”

Define “high and moderate non-conformant structures” as used here.

Response to Question 02:

The term “high and moderate non-conformant structures” refers to non-conforming structures that contain either a Level 1 (high) or Level 2 (moderate) condition as defined in General Order No. 95 Rule 18.