

*Southern California Edison*

**R.18-10-007 – SB 901**

**DATA REQUEST SET M G R A - S C E - 0 0 1**

**To: MGRA**

**Prepared by: Thomas Brady**

**Job Title: Senior Advisor**

**Received Date: 3/3/2019**

**Response Date: 3/7/2019**

---

**Question 11:** How many of the circuits specified in MGRA-1 have a weather station within 1/4 mile of some portion of the circuit? Please specify answers for distribution and transmission circuits separately.

**Response to Question 11:**

The data stated in this question is current as of 3/5/2019. 91 distribution circuits have a weather station within 1/4 mile of some portion of the circuit. 35 transmission/subtransmission circuits have a weather station within 1/4 mile of some portion of the circuit. The number of distribution and transmission circuits that have a weather station within 1/4 mile of some portion of the circuit will increase as wildfire mitigation efforts continue.