

Southern California Edison
2023-WMPs – 2023-WMPs

DATA REQUEST SET Cal Advocates - SCE - 2023 WMP - 22

To: Cal Advocates
Prepared by: Angeli-Ann Kim
Job Title: Senior Advisor
Received Date: 10/11/2023

Response Date: 10/19/2023

Question 005:

- a) Please provide SCE's definition for "GO 95 Exception."
- b) Please identify the reference or document from which the definition in question (b) is derived or based upon?

Response to Question 005:

- (a) A General Order 95 (GO 95) exception applies when an external constraint prevents a utility from completing work within a compliance timeframe. There are several scenarios which qualify for a GO 95 exception, the most common being: (1) permit required, (2) third party refusal, and (3) no access.
- (b) SCE's definition is based on General Order 95, Rule 18, which states that correction times can be extended under reasonable circumstances.