

Southern California Edison
2023-WMPs – 2023-WMPs

DATA REQUEST SET T U R N - S C E - 0 0 5

To: TURN
Prepared by: Hunly Chy
Job Title: Manager
Received Date: 5/5/2023

Response Date: 5/10/2023

Question 01 :

For the distribution circuits on which SCE plans undergrounding in 2023, please provide SCE's best estimate (which may be a rough approximation, if that is the best estimate) of the percentage of overhead conductor in the affected circuits (including primary, secondary and service conductor) that will be removed as a result of the planned undergrounding mileage in 2023. Please explain how SCE made this calculation and provide all inputs and assumptions.

Response to Question 01 :

As stated in response to TURN-02, Q6, for 2023 scope, SCE plans to underground 11 miles of primary lines, with 11 miles of overhead primary line removed.