

Southern California Edison
2023-WMPs – 2023-WMPs

DATA REQUEST SET S P D - S C E - 2 0 2 3 - 0 0 3

To: SPD
Prepared by: Tram Camba
Job Title: Wildfire Safety – Sr Advisor
Received Date: 5/15/2023

Response Date: 6/8/2023

Question 02:

Provide the utility's cost estimate breakdown for undergrounding per mile. Provide the cost estimate in a commonly used cost-estimating format (e.g., Uniformat). If the utility uses a different format, provide internal documentation on that format so SPD can understand the cost estimate.

Response to Question 02:

Please see the attached spreadsheet, "SPD-SCE-2023-003 Q2 Cost Estimate.xlsx," showing how SCE derives its weighted unit costs for the 2023-2028 period, as depicted in SCE's 2025 GRC TUG workpaper. This workpaper details how the unit costs are developed in consideration of the anticipated level of difficulty, composition of primary, secondary, and service lines, meter relocations, escalation, and environmental costs. Note that the anticipated level of low, medium, and high difficulty is preliminary and could change as each project goes through the planning/design and final construction process.